



**LIMITED LIABILITY COMPANY  
“UST-KAMENOGORSK CAPACITOR  
PLANT”**

**Capacitor banks UKRM 56(57)  
(Questionnaire for Purchase Order)**

“UKCP”, Ltd. reserves its right to a property of this document in accordance with the existing rights. This document can not be copied, reproduced, or published without prior permission.

Name of company:
Performer:
Contact information:  Phone: _____ Mobile Phone: _____ Fax: _____ E-mail _____

<b>№</b>	<b>Parameter</b>	<b>Customer requirements</b>	<b>Performance variant</b>
1	Type of capacitor bank	UKRM 56(57)	
2	Location of input cell (left/right)		
3	Presence of input disconnecter with grounding (yes/no)		
4	Rated voltage, kV (6,3;10,5)		
5	Rated power, kVAr		
6	Rated frequency, Hz		
7	Mode of input (from top/below)		
8	Power of constant step, kVAr (in case of presence)		
9	Quantity and power of regulation steps pcs./kVAr		
10	Presence of communication interface		
11	Power supply voltage of secondary (auxiliary) circuits, V		
12	Control and measuring instruments (analogue, digital)		
13	Climatic category type as per GOST 15150-63 (U1, U3, UHL1(container))		
14	Protection degree as per GOST 14254-80		
15	Additional requirements		

Instrument current transformer installed in front of compensation object is required for automatic capacitor bank operation. Instrument voltage transformer is required for banks operation at voltage 6/10 kV.

Additional equipping of capacitor bank with anti-resonance throttles is necessary in case of incompliance of electric energy quality parameters.